

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

CiDRA Corporate Services LLC

50 Barnes Park North, 06492 Wallingford, CT, USA

the Certificate No: **Z01435** for the PROFIBUS device:

Model Name: SONARtrac
 Revision: 1; SW/FW: 2.20; HW: 1.00
 GSD: CIDR0BD6.gsd, File Version: 2.20
 PA139700.gsd

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/>	DP-V0	MS0, Fail_Safe, Set_Slave_Add
<input checked="" type="checkbox"/>	DP-V1	MS2, I&M
<input checked="" type="checkbox"/>	Profile	PA Devices V 3.01
<input checked="" type="checkbox"/>	Physical Layer	MBP

Test Report Number: 672 PA 01/01
 Authorized Test Laboratory: itm, Munich, Germany

The tests were executed in accordance with the following documents:
 "Test Specifications for PROFIBUS DP Slaves, Version 3.0 from November 2005" and
 "Test Specifications for PROFIBUS PA Profile 3.0.1, Version 4.9 from February 2007".

This certificate is granted according to the document:
 "Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by **July 20, 2021** the certificate is valid for life.

Karlsruhe, April 26, 2018



(Official in Charge)



Board of PROFIBUS Nutzerorganisation e. V.



(Karsten Schneider)



(Dr. Jörg Hähnliche)